

Soudal FIRECRYL FR

Revision: 17/02/2014

In Accordance with the CPR, Regulation (EU)N°305/2011

Page | 1

Reference No: 230011

1. Unique identification code of the product-type:

Soudal FIRECRYL FR

2. Identification of the product according article 11 part 4

See batch number on the product

3. Intended use or uses of the construction product:

Fire sealing product for linear joints and gap seals.

4. Accordance with the applicable harmonised technical specification:

ETAG 026 Part 1: General**ETAG 026 Part 3: Linear joint and gap seals**

5. System or systems of assessment and verification of constancy of performance of the construction product, as set out in Annex V:

System 1**System 3: for reaction to fire**

6. Name and contact address of the manufacturer as required pursuant to Article 11(5):

**Soudal NV,
Everdongenlaan 18-20,
2300 Turnhout,
Belgium**

7. The notified body:

Belgian Construction Certification Association (founders BBRI and SEC) with accredited certificationbody N° 21 has carried out Initial Type Testing under system 1, and issued the following report: AG110308-E ETA 13/0335

Soudal FIRECRYL FR

Revision: 17/02/2014

In Accordance with the CPR, Regulation (EU)N°305/2011

Page | 2

8. Declared performance:

Essential characteristics	Performance/ Harmonised tech.spec.
Reaction to fire	Classe E according EN 13501-1
Resistance to fire	Performance resistance to fire according EN 13501-2 See ATE 13/0335
Release of dangerous substances	See ATE 13/0335 section 2.2.3
Use category	Z 2(-5/+40) according Etag -TR024

The performance of this product is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the manufacturer.

Signed for on behalf of the manufacturer by:

Turnhout, 17/02/2014


Ing. G. Franssen
Technical Service